

ADDENDUM NO. 2

CITY OF SAN ANTONIO
CAPITAL IMPROVEMENTS MANAGEMENT SERVICES

PROJECT NAME: **Safe Routes to School**

DATE: 5/29/12

This addendum should be included in and be considered part of the plans and specifications for the name of the project. The contractor shall be required to sign an acknowledgement of the receipt of this addendum and submit with their bid.

CIMS PROJECT NO.: **40-00238 & 40-00239**

QUESTIONS & ANSWERS

Question: Does the bridge have concrete or metal floor? If it is concrete how will it be paid?

Answer: The initial question was associated with payment for the bridge deck, which we answered. There is no real "elevated sidewalk", the sidewalk is pretty much on grade, for exception of the tie-in (less than 6 linear feet) to the bridge, but is less than 1 foot at one end of the bridge, and less than 2 on the other. We also call for retaining wall. To summarize, this item is simply a sidewalk, and paid as such.

**CITY OF SAN ANTONIO
DEPARTMENT OF CAPITAL IMPROVEMENTS MANAGEMENT SERVICES
CONTRACT SERVICES DIVISION**

RECEIPT OF ADDENDUM NUMBER(S) 2 IS HEREBY ACKNOWLEDGED FOR PLANS AND
SPECIFICATIONS FOR CONSTRUCTION OF Safe Routes to School

FOR WHICH BIDS WILL BE OPENED ON WEDNESDAY, May 30, 2012 AT 2:00 P.M.

THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH
THE BID PACKAGE.

Company Name: _____

Address: _____

City/State/Zip Code: _____

Date: _____

Signature

Print Name/Title